



CITY OF MIRAMAR

Department of Utilities Engineering Services Department

REQUIREMENTS FOR CCTV INSPECTION DATA

Please note: Prior to submitting TV inspection data to the Department of Utilities/Engineering Services, the following criteria for the data being submitted must be met.

- 1. Code system of the CCTV inspection data submitted must be in NASSCO's PACP (Pipeline Assessment & Certification Program) format.**
- 2. Must be able to export the data in NASSCO PACP Version 7.01 Exchange Access Database format with video and image files provided.**
- 3. Video and image file names must be less than 50 characters long.**
- 4. Must use exact Manhole IDs as supplied by the City**
 - a. For example: MH017-031**
- 5. Pictures of defects are required to be taken and furnished to the city.**
- 6. Contractor is to submit a reference binder as the final report containing the following:**
 - Name of the company**
 - Profile Report/ Main Section for each section videotaped**
 - Inspection Report**
 - In addition to other required NASSCO pipe conditions, it is required that upstream and downstream manhole rim to invert measurements are reported for every segment of pipe reported.**
 - Inspection photos**
 - Data storage: DVDs, USB flash drive, or external USB SSD hard drive with the company logo affixed to the data storage media/device containing inspection data in PACP format as mentioned above.**